



PORT GAMBLE S'KLALLAM TRIBE

Planning Department

31912 Little Boston Road NE • Kingston, Washington 98346

NRE Building replacement Site Walk through Clarifications Part 2:

As part of installing buildings in the Tribal campus area, the Tribe requires the buildings to be set up with the following contracted through Intellisystems:

- an addressable Fire panel(Non-Proprietary)
- Addressable smoke detectors
- Addressable pull system
- Addressable heat detector
- Horn strobe
- Back up Battery -12 volt 7amp/hour
- AES-Intellinet Mesh Fire Transceiver(intellinet2.0) with intellitap.
- Fire Alarm monitoring -AES Mesh network Radio.

If you have any questions about the Alarm system, contact Intellisystems of Port Orchard.

Please contact Rory McLeod with any questions at Rorym@pgst.nsn.us or 360-981-9614